City of Apple Valley

MEMO

Building Inspections

TO: Kathy Bodmer, Planner

FROM: George Dorn, Building Official

DATE: August 9, 2017

SUBJECT: Portillo's

- Separate sign permits are required.
- SAC determination is required from Met Council prior to permit issuance from the city.
- Submit plans to the Department of Health if food is being served prior to permit issuance from the city.
- Hard Copy of Geotechnical report boring log and Special Inspector Agreement is required prior to permit and soil corrections on site.
- Trash area is required per MSBC 2015 1303.1500 Subpart 1 requires recycling space in accordance with Table 1-A on plans issued for permit.